

**KANNUR UNIVERSITY**  
**PLANNING AND DEVELOPMENT BRANCH**  
**QUOTATION NOTICE**

PI.D/PLD-B2/ 6701/2019 (Part IV)

Date:25.10.2022

Kannur University invites Quotations for the supply and Installation of Energy meter and DB fixing works for Cafeteria at Student Amenity Centre, Thavakkara Campus,Kannur with the specifications annexed herewith. The eligible and interested vendors may quote the rate and send to “**The Registrar, Kannur University, Thavakkara Campus, Civil Station P.O, Kannur-670002**” on or before 10.11.2022 **at 2.P.M** and the quotations will be opened **at 3.P.M** on the same day. Please visit the website” **www.kannuruniversity.ac.in** ” for more details.

Sl.No.	Quantity	Description	Unit	RATE IN FIGURES	AMOUNT	REMARKS
1	1	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 V, on surface, recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCBIRCCB/Isolator.2*12 way, Double door	each			
2	6	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.Single pole	each			
3	2	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.40 amps	each			
		Supplying and fixing following rating, double pole, (single phase and neutral), 240 V,				

4	1	residual current circuit breaker (RCCB), having a sensitivity current 30 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required.40 amps	each			
---	---	--	------	--	--	--

Sl.No	Quantity	Description	Unit	RATE IN FIGURES	AMOUNT	REMARKS
5	35	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface /meter recessed medium class PVC conduit as required,2X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire				
6	10	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface /meter recessed medium 2 X 6 Sq.mm + 1 x 6 sq.mm earth wireclass PVC conduit as required				
7	1	Single phase KWh meter, 240 V, 10 - 40 A ,electronic type energy meter - accuracy class 1	each			
8	1	Single Phase Meter Box with Isolator Option(Powder Coated"Ivory")	each			
		Total Amount				

\*Rate shall be inclusive of all applicable taxes

## **SIGNATURE**

### **Name & Address of the Quotationer**

#### **Terms and Conditions**

1. Quoted rate should include all applicable taxes, other charges, if any.
2. The Details of warranty conditions and firm's history in this field should be provided along with the quotation.
3. Quotation should be valid for a minimum period of three months.
4. The undersigned reserves the right to reject any quotations without assigning any reason thereon.

Sd/-

**REGISTRAR(i/c)**

**To**

1. **Website**
2. **Notice Board**