KANNUR UNIVERSITY

Planning & Development Branch (C Section)

PLD/PLD-C3/14417/2019

Dated 06.06.2023

NOTICE INVITING QUOTATIONS

Sealed Quotations are invited from interested PWD Licensed Contractors/ Firms for Supply and Installation of Water Purifying System at the Hostel & Canteen at Dr. Janaki Ammal Campus of Kannur University.

Quotations with all relevant details should reach the Registrar, Kannur University, Thavakkara Civil station-PO, Kannur on or before 20.06.2023, 3.00PM and will be opened at 3.30 PM on the same day.

Conditions

- 1. The rate should be inclusive of all Taxes and nothing extra shall be admissible over and rate quoted.
- 2. The Payment will be made through Account payee cheque and no Advance payment will be sanctioned.
- 3. Work shall be completed in 20 days from the date of Agreement.

The Registrar, Kannur University reserves the right to reject any of the Quotations or all the Quotations without assigning any reasons whatsoever.

To

- 1. Notice Board
- 2. Website
- 3. Engineering Wing

Registrar (i/c)

1

SL. NO	QTY	PARTICULARS	UNIT	RATE		AMOUNT
				IN FIGURES (RS)	IN WORDS	(RS)
L	1	Supply and installation of vessel filter units. (1354 vessel softener dia 13" and height 54", the each filter system 2500 ltr to 3000 ltr water purifying in every hour,will install on top of the building tank outline,connected with inlet filter through below floor supply purified water in gravity pressure .(3 to 4 bar),This softener need to make back wash in every week do to protect head of the filter.(In the system itself MPV just turn position back wash mode) following specifications for one filter: (1)14 65 Media activated Carbon filter (1 no) (2)Activated Carbon indo german (25 kg) (3)DMI 65 (42 kg) (4)40 mp valve (2 no) (5)Sylex (50 kg) (6)Quarts sand (50 kg) (7)Fine sand (50 kg) (8) 1054 softner (1 no) (9)Ressin media (25 kg) rate is inclusive of cost of all labour charges and scaffoldings etc,complete.	nos			
		Name Of Work: Supply and installation work of inlet valve of water fi alayad Campus Supply and installation of vessel filter units. (1354 vessel softener dia 13" and height 54", the each filter system 2500 ltr to 3000 ltr water purifying in every hour, will install on top of the building tank	ltration	units at Ladies	Hostel,	
	3	outline, connected with inlet filter through below floor supply purified water in gravity pressure .(3 to 4 bar), This softener need to make back wash in every week do to protect head of the filter.(In the system itself MPV just turn position back wash mode) following specifications for one filter:- (1) 13 54 Media activated Carbon filter(1 no) (2) Activated Carbon indo german(8.3 kg) (3) DMI 65 (14 kg) (4) 40 mp valve (1 no) (5) Sylex(33.3 kg) (6) Quarts sand (33.3 kg) (7) Fine sand (33.3 kg) rate is inclusive of cost of all labour charges and scaffoldings etc , complete	nos			
			1			
+		Total				
+		Add 18 % GST				
	***	Grand total				
atu	e:					