

**KANNUR UNIVERSITY**  
**(PLANNING AND DEVELOPMENT BRANCH)**  
**NOTICE INVITING RE TENDER**

No.PID/E1/24038/2019

Dated:19.05.2021

Sealed competitive re tender super scribed as "Oil filtering and maintenance of 250 KVA Transformer and Yard at P.K Rajan Memorial Campus ,Nileswaram" of Kannur University are invited from registered competent electrical Contractors/firms.

Sl.No	Name of Work	EMD	TENDER FEE	Time for the completion of work	Last date and time of submission
1	2	3	4	5	6
1	Oil filtering and maintenance 250 KVA Transformer and yard at Nileswaram Campus	2950	₹500/- + GST (12%)	1 month from the date of agreement	27.05.2021 at 3 PM

- 1.Tender Form can be downloaded from the Kannur University Website [www.kannuruniversity.ac.in](http://www.kannuruniversity.ac.in).
- 2.A sum of ₹ 500/- + GST (12%) towards the cost of Tender form and an amount of ₹2,950/ as EMD should be remitted separately by way of Demand Draft drawn in favour of Finance Officer, Kannur University,payable at SBI South Bazar Branch, Kannur or Kannur Branch of any other Nationalized or scheduled Bank.
- 3.The tenderer should send along with the tender an initial agreement executed and signed in Kerala Stamp Paper of value ₹200/-
- 4.The tenderer shall have valid GST registration and shall furnish a copy of registration certificate along with the tender documents.
- 5.The successful tenderer before signing the Agreement and within the period specified in the work order, shall deposit a sum equivalent to 5% of the value of the contract as Security Deposit.
6. The rate quoted should be inclusive of GST and all other charges if any. The base rate, GST charges and other charges if any should be furnished separately and nothing extra shall be admissible over and above the rate quoted.
7. Payment will be made through account and no advance payment will be sanctioned
8. Received tenders will be opened on 27.05.2021 at 3.30 PM.

Details of work can be had from the Planning and Development Branch on all working days up to 5 pm.

The Registrar, Kannur University, reserves the right to reject any of the tenders or all the tenders without assigning any reason whatsoever.

Sd/-  
REGISTRAR(i/c)

To : 1.Notice Board.  
2.Website.



**KANNUR UNIVERSITY**  
**TENDER SCHEDULE**

**NAME OF WORK : OIL FILTERING AND MAINTENANCE OF 250 KVA TRANSFORMER  
AND YARD AT NILESHWARAM CAMPUS**

**Last date of submission on 02.2021**

<b>SL.No.</b>	<b>Quantity</b>	<b>Name of work</b>	<b>Rate</b>	<b>Amount</b>
1.	260 Ltr.	Filtering and purification of transformer oil, removing all impurities like silts, coarse, moisture and improving the property of existing transformer oil using VFD filtering plant and refilling the transformer including BDV test and produce Test report.		
2.	30Ltr.	Supply conveyance and filling extra quantity of new transformer oil to maintain the level in the transformer in place of removed contaminated ground/slit leakage or by evaporation etc.		
3.	1 No.	Scrapping and painting 250 KVA transformer with grey colour best quality enamel paint over a coat of red oxide/sinchronate primer including painting all the fence and base frame after isolating the HT line and ensuring the safety by informing KSEB as per rule.		
4.	75 sqm	Re painting the four pole out door substation structure made with MS channels, angle iron mounting arrangement ;of AB switch, insulator etc, Scrapping and painting with Aluminum paint to the HT 4 pole structure after isolating the HT line and making in good and painting the outer surface of HT metering Kiosk.		
5.	70 sqm.	Scrapping, Repainting of the both sides of the fancing pillars and fencing grills of transformer yard with best quality enamel paint and making in good appearance (sinchronate primer including)		
6.	70sqm	Removing the grass, cleaning, leveling inside the 4 pole structure yard, tilting of granite metal with foarks after removing weeds from the transformer yard and refilling after cleaning to make good appearance		
7.	4 Nos.	Supply and replacing defective HT pin insulator suitable for 250 KVA out door type transformer yard with new set of pin insulator after disconnecting the damaged pin insulator, disconnecting the HT line from KSEB on proper intimation.		

8	3Nos.	Supply and replacing the damaged lightning arrestor for 250 KVA transformer yard with new lightning arrestor after disconnecting the HT line from KSEB on proper intimation.		
9	1 No.	Supply and replacing defective breather with new silica gel breather for 250KVA transformer, if required.		
10	1 No.	Supply and fixing three insulator 11 KV gang operated AB switch with all accessories in the existing 4 pole structure and removing the existing faulty AB switch unit etc, as required		
11	1 No.	Checking the existing 11 KV/415V, 250KVA transformer, megering, checking and tightening the HV/LV side terminals, clearing, tightening the earth connections and replace damaged nut and bolts, display the earth value.		
12	1No.	To and from transportation of transformer filtering plant and testing unit to site as required		
13	50sqm	Painting with Silicon & acrylic emulsion based water thinable sealer of approved brand and manufacture on wet or patchy portion of plastered surface etc, complete as required (2 or more coat) (on DG Shed)		
14	50sqm	Scraping and painting with synthetic enamel paint at approved brand and manufacture to give an even shade (2 or more coat) panel board etc.		
		<b>Total</b>		
		<b>GST</b>		
		<b>Grand Total</b>		<u>                    </u>

**Contractor**

**REGISTRAR(i/c)**